QA/QC Requirements for Opacity Monitors

EPRI 2013 CEMS User Group Conference Raleigh, NC – May 8, 2013

By Dru Sanders
RMB Consulting & Research, Inc.

QA/QC for COMS

- Currently No Federal Requirement for Ongoing QA/QC Requirements for COMS
- Requirements Vary From State to State
- COMS QA/QC Originally Proposed (Method 203)
 1992
- EPA Decided to Completely Redraft Method –
 2001
- Re-proposed as Procedure 3 (App. F, Part 60) 2003

QA/QC for COMS

- Procedure 3 Published In Federal Register as Direct Final Rule on 2/14/2012
- **♦** Compliance Required Beginning 4/16/2012
- **EPA** Withdraws Rule Due to Adverse Comments
- Anticipated That EPA Would Reissue Procedure 3 in 2013
- Presentation Should Provide Overview of Requirements & Level of Effort For Compliance

Proposed Procedure 3

- Quality Assurance Requirements for Continuous Opacity Monitoring Systems (COMS) at Stationary Sources
- "Applies to COMS used to demonstrate continuous compliance with opacity standards in federally enforceable regulations"
 - Concern for State regulations with blanket Part
 60 Appendix F references

Proposed Procedure 3

- Performance Specification 1 (PS-1) References –
 May Be a Concern for Pre-2001 COMS
- Daily, Quarterly & Annual QA Requirements
 - Daily Zero/Upscale Drift and Status Indicator Checks
 - Quarterly Optical Alignment Check, Zero Compensation Check, and Calibration Error Test (Filter Audit)
 - Annual Zero Alignment Check
- Data Capture Requirements

Daily QA/QC

- Daily Calibration Drift Test
 - Zero and upscale calibration
 - Out-of-control if CE > 4.0%
- Daily Status Indicator Check
 - Data invalid if indicators are "illuminated"
 - Initiate corrective action

Quarterly QA/QC

- Optical Alignment Check
 - Stack temperature ± 50% typical operating temperature
 - Out-of-control if alignment > 3% opacity
 - Data validation
- Zero Compensation Check
 - Out-of-control if zero compensation > 4% opacity

Quarterly QA/QC

- Calibration Error Test
 - References PS-1 procedures
 - Three (3) nonconsecutive readings for each of the three (3) filters
 - Filters calibrated every six (6) months
 - Out-of-control if CE > 3% opacity
- May Request Semi-Annual Test Frequency For Quarterly Audits

Annual QA/QC

- Primary Zero Alignment Check
 - Off stack or on stack
 - On stack clear path demonstration
 - Out-of-control if zero alignment error > 2% opacity
 - Off stack zero alignment check required at least once every three (3) years

Annual QA/QC

- Alternate Zero Alignment Check
 - Use external COMS specific zero-jig
 - Record initial zero-jig response, then conduct zero alignment procedure
 - If zero-jig is adjusted, must conduct an off stack zero alignment check

QA/QC Corrective Action

- Revise Procedures or Repair/Replace COMS, If COMS Fails:
 - Two consecutive annual audits
 - Two consecutive quarterly audits
 - Five consecutive daily checks

Data Capture Requirements

- Must Capture Data For At Least 95% of the Operating Hours Per Calendar Quarter (Section 10.4(4))
 - Out-of-control data not used
 - Excludes downtime associated with required QA/QC procedures
- ◆40 CFR 60.13(h)(1)
 - 6-minute avg. calculated from 36 or more equally spaced data points

Temporary COMS Replacement

- May Use Temporary COMS Replacement
 - COMS ASTM D 6216 certified
 - Limited to 720 hours (30 days) per year
 - May not install a second temporary COMS
 - Complete full PS-1 certification after 720 hours

Temporary COMS Replacement

- **◆ Temporary COMS Test Requirements**
 - Off-stack clear path assessment
 - Optical alignment check
 - 7-day calibration drift test (Abbreviated)
 - Conducted within 24-hr period & no more than one (1) calibration every three (3) hours, and
 - > Not less than one (1) calibration every 25 hours
 - Calibration error test

Corrective Action Requirements

- Rule Identifies Five (5) Maintenance Classes
 - Routine/Preventive Maintenance
 - Measurement Non-Critical Repairs
 - Primary Measurement Light Source
 - Measurement Critical Repairs
 - Measurement Critical Repairs (Not Optics)
- Part 75 Diagnostic Test Concept

Corrective Action Example

- Primary Light Source Repair Requires:
 - Daily Calibration Drift Test
 - Fault Indicator Check
 - Optical Alignment Check
 - Zero Alignment Check
 - Calibration Error Check

Recertification Requirements

- Rebuild or Substantially Refurbish COMS
 - Replace "major sub-assembly or lesser sub-assemblies with different revision levels..."
- Change To, or Addition of COMS
 Components Which May Affect MCOC

 Performance Parameters
- Complete PS-1 Certification

General Requirements

- Develop Written QA Plan
- Written Procedures Available for Inspection
- Quarterly Data Assessment Report (DAR)
 - References DAR in Procedure 1
 - Monitor availability
 - QA/QC test results
 - Corrective actions taken

Procedure 3 Issues

- 720 Operating Hours (30 Days) Clarify to 720 Unit Operating Hours
- Monitor Availability Requirements
- Disconnect Between Hourly Availability &
 6-minute Average Requirements
- **♦ No Conditionally Valid Data Procedures**
- **♦ PS-1 References**